



V.11/2016


For guidance on managing construction health risks go to [www.hse.gov.uk/construction](http://www.hse.gov.uk/construction)

For guidance on managing construction health risks go to [www.hse.gov.uk/construction](http://www.hse.gov.uk/construction)

For guidance on managing construction health risks go to [www.hse.gov.uk/construction](http://www.hse.gov.uk/construction)

# Festoon & Flood Lighting

The rules and procedures in force where people are at work may require the person responsible for this equipment to carry out a specific risk assessment.



**It is important to read all of this leaflet BEFORE using Festoon & Flood Lighting**

Plan each task and try to foresee any problems that may occur so they can be dealt with safely.

Electricity is dangerous and must always be used with great care.

- Water and electricity make an extremely dangerous combination. Keep electrical equipment away from rain and water.
- The following items of personal protective equipment are a minimum: rod if using a 230 volt (mains) supply.
- Particular items of equipment or environments may require a higher level of personal protective equipment.
- Lighting equipment must not be installed by minors, or by anyone under the influence of drugs or alcohol.
- Lighting equipment is designed for installation by an able bodied adult. Anyone with either temporary or permanent disability must seek expert advice before using it.



Every effort has been made by HAE/EHA to ensure that the information given in this document and supporting material is accurate and not misleading. HAE/EHA cannot accept responsibility for any loss or liability perceived to have arisen from the use of any such document/material. Only Acts of Parliament and Statutory Instruments have the force of law and only the courts can authoritatively interpret the law.

**HAE**  
THE ASSOCIATION EUROPE  
Hire Association Europe  
2450 Regents Court  
The Crescent  
Business Park  
Salford B57 7YE

Telephone: 44 (0) 121 380 4600  
Fax: 44 (0) 121 333 4109  
Email: [mail@hae.org.uk](mailto:mail@hae.org.uk)  
Website: [www.hae.org.uk](http://www.hae.org.uk)

# Using the Lighting Equipment

- Ensure that nobody is staring at a powerful light when it is switched on – the dazzle can cause temporary blindness.
- Check that cable runs are being kept safe, and are not causing a hazard.
- If a cable appears to be cut or damaged in any way, switch off and unplug at the mains before inspecting it. If the cable attached to a light is damaged, stop using the light. Contact the hire company. If an extension cable has been damaged, do not use it again.
- Check that no combustible material, such as paper or rubbish, is too close to powerful and hot lights.
- Switch off lights before adjusting their position.
- Switch off and unplug lights before moving them to a new location.
- Switch off and unplug before leaving portable lights unattended.
- Before switching off general or festoon lighting, make sure no one is going to be put in danger by the drop in lighting levels.
- If the lights are left in place for more than a week, then a competent person should inspect them every week to ensure they are safe.
- If the equipment does not work properly do not attempt to repair it, contact the hire company.

**Please keep this leaflet safely as it may be required for future reference**



**HAEH**  
THE ASSOCIATION EUROPE  
Hire Association Europe  
2450 Regents Court  
The Crescent  
Business Park  
Salford B57 7YE

Telephone: 44 (0) 121 380 4600  
Fax: 44 (0) 121 333 4109  
Email: [mail@hae.org.uk](mailto:mail@hae.org.uk)  
Website: [www.hae.org.uk](http://www.hae.org.uk)

# CHANGING BULBS

- Make sure that you have the correct replacement bulb ready. Check with the hire company if in any doubt.
- Do not touch halogen bulbs with bare fingers as this will shorten the life of the bulb.
- When the light bulb has been changed, replace all covers and guards properly and secure any screws or clips.
- Look away before plugging in and switching on as powerful lights can dazzle.

**Any unauthorised reproduction – manually or electronically – is STRICTLY prohibited**



©Copyright Hire Association Europe April 2011

# CHANGING BULBS

- Make sure that you have the correct replacement bulb ready. Check with the hire company if in any doubt.
- Do not touch halogen bulbs with bare fingers as this will shorten the life of the bulb.
- When the light bulb has been changed, replace all covers and guards properly and secure any screws or clips.
- Look away before plugging in and switching on as powerful lights can dazzle.

**Any unauthorised reproduction – manually or electronically – is STRICTLY prohibited**



©Copyright Hire Association Europe April 2011

# WORK AREA

# EQUIPMENT

# Before Starting Work...

- Do not use electrical equipment where there is a danger of explosion. It may ignite fumes from petrol or gas cylinders.
- Keep electrical equipment away from rain and water.
- Ensure there are no combustible materials near floodlights. A floodlight can produce a much heat as a 1kw electric radiant heater and can cause paper and cloth to ignite, check that no loose paper or rubbish can be blown into the area heated by the light.
- For stand lights, choose an area where they are going to be safe from vehicles, people, water, rain, strong gusts of wind and other hazards which may damage them or knock them over. The ground should be firm and level.
- For lights fixed to buildings or fixtures, make sure that their support is strong enough and secure. Take care to position lights up and away from where they may get struck by passing vehicles, people or materials being carried.
- In all cases, plan cable runs to avoid damage to the cables, and so that the cables themselves do not form a tripping hazard in doorways or walkways.
- In areas where members of the public are allowed, it may be necessary to put barriers around lighting stands to keep people away from the heat and to prevent them tampering with the light.

- Check the equipment cables, plugs, sockets and stands. If anything is found damaged, do not use it – contact the hire company.
- Check that the plugs on the cables match the supply. Do not try to force connections or improvise them.
- Equipment with a cylindrical yellow industrial plug fitted is designed to run off a special 110V supply. The hire company will have provided a portable transformer if the equipment requires powering from a normal mains 230V supply. If a portable transformer has been supplied, take care not to injure yourself when moving it about – it may be heavier than you think.

- The equipment will only operate on one voltage: it will be 110V or 230V. 110V lighting will have a yellow industrial plug fitted. 230V lighting will have either a normal square pin plug fitted or a blue industrial plug. Read the instructions below for the equipment.
- 110 VOLT LIGHTING (YELLOW PLUG)**
  - If using a portable transformer, plug the transformer directly into the 230 volt socket. Do not use any 230V extension cables.
- 230 VOLT LIGHTING (SQUARE PIN OR BLUE PLUG)**
  - Use a residual current device (rcc) plugged directly in to the 230 volt socket. Plug the lighting into the rcc. This will help to protect against electric shock if the cable or lights are damaged.
  - Make sure that any extension cable connections are dry and safe.
  - Use a suitable construction site 230V EQUIPMENT ON CONSTRUCTION SITES
    - If 230V is selected for equipment on construction sites or similar environments, the risk of injury or death arising from the use of damaged or faulty equipment is high unless special precautions are taken. The precautions must reduce the risk to an acceptable level.
    - Health and safety authorities consistently recommend 110V systems as the best solution for reducing risk from portable, hand-held, and transportable equipment. A risk assessment carried out by the planning supervisor (or other person is likely to indicate that risk of electric shock is most effectively controlled by the use of 110V equipment.
    - Some suitable precautions are shown below. Some of these precautions can be provided by the electricity supply on site. Other precautions, however, fall to you, the user.
      - Protect people who may receive an electric shock by fitting non-adjustable residual current devices (rccs). Rccs should be installed either at the distribution board which feeds to main supply sockets or at the fixed main supply socket. In either of these positions they will provide protection from faults in both the cable and light. Rccs fitted close to the light only protect faults in the light.
      - Rods should be:
        - installed in a dustproof and weatherproof enclosure (see the manufacturer's instructions for use in dusty and outdoor environments;
        - protected against mechanical damage and vibration;
      - checked daily by operating the test button;
      - inspected weekly together with the formal visual inspection;
      - tested every three months by an electrician using appropriate electrical test equipment. Note: the tests should not be carried out on rods at a time when loss of power may adversely affect other work activities.
    - Reduce the risk of flexible supply leads being damaged by:
      - positioning them where they are less likely to be damaged (e.g. run them at ceiling height inside a building); and/or
      - protecting them inside impact resistant conduit where appropriate; or
      - using special abrasion resistant or armoured flexible supply leads where appropriate; or
      - Select equipment that is designed for trade and work use. Double insulated equipment is strongly recommended where it is necessary to use a mains voltage supply, because the equipment itself is less likely to give rise to danger. Danger can still arise, however, if the cables, plugs or equipment casing are damaged. Any restrictors on use set out in the manufacturer's or suppliers instructions should be observed.

Continued